

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHI/Water/BCA/ 97 /2023-24

Date: 30/05/2023

It is certified that an inspection team headed by Dr. Girija . B, Administrative Medical Officer (Name of the Officers with designations) from Community Health centre, Kengeri (Name of Department/Office) along with Mr./Mrs. G.M. Nara Simhaiah, designation Health Inspector and the team inspected (Name and Address of the School) Airaa Academy, Sy.No. 55/6, 55/7, 55/8, Hemmigeपुरa main road, Banashankari 6th stage, Kengeri Hobli, Bangalore- 560 060 on date: 17/05/2023, collected the water samples & has been sent to Public Health Institute, Bangalore, Govt. of Karnataka for lab tests. Based on Bacteriological analysis of water/effluent samples (No.30c & 30b) report No.PHI/Water/BCA/ 97 /2023-24, dated: 17/05/2023, and found that the Airaa Academy (Name of the School) has safe drinking water facilities for the students and the members of the staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of one year from date of issue.

Signature with seal:

Name:

Designation:

Dr. GIRIJA B.

MBBS Dch

KMC Reg. No 57121

Senior Specialist

**COMMUNITY HEALTH CENTER
KENGRI, BENGALURU-60**

To
The Principal
AIRAA ACADEMY,
Hemmigeपुरa main road,
Banashankari 6th stage,
Kengeri Hobli,
Bangalore- 560 060.

For AIRAA ACADEMY


CHAIRMAN

For AIRAA ACADEMY



GOVERNMENT OF KARNATAKA

No:PHI/Water/BAC/97/22-23

Office of the Joint Director
Public Health Institute
Bangalore - 560 001

Dated: 20/5/23

Report of Bacteriological analysis of Water / Effluent sample

Sample sent by:	Sample No	Source & Particulars of Water Sample	Opinion			S.P.P	N.S.P.P	N.S.P.P & FC.
			M.P.N Count	Plate Count	D.C Test			
ಅಸ್ಥಾನ ವ್ಯವಸ್ಥಾಪಕರು ನಿಜು ನಾಯಕ ಅಧೀನ ಶಿಕ್ಷಣ ಕಚೇರಿ ಬಿ. ಎ. ಸಿ. ಸಿ. ೨೦	305	AIRAA Academy ಬೆಂಗಳೂರು ವಿಜಯ ನಗರ ೨೨	nil	-	-	SPP	-	-
Note: M.P.N Count: Most probable number of Bacteria per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E. Coli found.	306	School Henige Pura -ವಿಜಯ ನಗರ ೨೨	nil	-	-	SPP	-	-

For AIRAA ACADEMY

[Signature]
CHAIRMAN

For AIRAA ACADEMY

[Signature]

For Joint Director(Labs)
PUBLIC HEALTH INSTITUTE
Bangalore

(PTO)

DR. GIRIJA B.
MBBS, DCH
KMC Reg. No. 57121
Senior Specialist
COMMUNITY HEALTH
KEM

Advice:

1. Sample.....

Need effective chlorination before use

2. Sample.....

Need to avoid possible source of faecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

For AIRAA ACADEMY

CHAIRMAN

For AIRAA ACADEMY

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E coli count per 100ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or more